

Proyecto: Unifamiliar Aislada
Promotor: -
Situación: Ibiza

Resumen de las comprobaciones												
Pilares	Tramo	Dimensión (cm)	Posición	Esfuerzos p�simos						P�sima	Aprov. (%)	Estado
				Naturaleza	N (kN)	Mxx (kN�m)	Myy (kN�m)	Qx (kN)	Qy (kN)			
				G, Q	178.0	-7.3	-10.5	-8.5	-4.1	N,M	21.1	Cumple
P17	F1 (0.1 - 3.6 m)	30x30	Cabeza	G, V, N	74.7	20.4	21.6	-7.2	-6.5	Q	21.8	Cumple
				G, V, N	74.6	19.6	22.1	-7.4	-6.2	N,M	75.3	Cumple
			Pie	G, V, N	84.3	-0.5	-1.7	-7.2	-6.5	Q	21.2	Cumple
				G, Q	87.6	-0.4	-1.8	-6.3	-6.9	N,M	6.2	Cumple
	Dep�sito	30x30	Arranque	G, V, N	84.3	-0.5	-1.7	-7.2	-6.5	Q	2.7	Cumple
				G, Q	87.6	-0.4	-1.8	-6.3	-6.9	N,M	6.2	Cumple
P18	F1 (-0.62 - 3.6 m)	30x30	Cabeza	G, V, N	95.2	19.3	12.5	-4.0	-5.8	N,M	49.1	Cumple
			Pie	G, V, N	105.4	-0.6	-2.1	-4.0	-5.8	Q	14.6	Cumple
				G, Q	114.1	-0.6	-2.3	-3.3	-6.2	N,M	8.1	Cumple
	Dep�sito	30x30	Arranque	G, Q, V, N	105.9	-0.6	-2.1	-4.0	-5.8	Q	2.0	Cumple
				G, Q	114.1	-0.6	-2.3	-3.3	-6.2	N,M	8.1	Cumple
P15	F1 (-0.48 - 3.1 m)	30x30	Cabeza	G, S	23.1	5.5	-17.8	18.1	-6.2	Q S.	43.6	Cumple
				G, V, N	26.2	0.2	-18.6	17.2	-0.2	N,M	38.1	Cumple
			Pie	G, S	29.3	-11.9	33.2	18.1	-6.2	N,M S.	66.6	Cumple
	Dep�sito	30x30	Arranque	G	21.3	-0.1	12.0	7.2	-0.1	Disp.	-	Cumple
				G, S	29.3	-11.9	33.2	18.1	-6.2	N,M S.	66.6	Cumple
P14	F1 (-0.48 - 3.1 m)	30x30	Cabeza	G, V, N	306.8	12.3	-46.5	29.6	-2.4	N,M	79.8	Cumple
			Pie	G, V, N	315.2	-12.6	55.0	29.6	-2.4	N,M	98.1	Cumple
	Dep�sito	30x30	Arranque	G	183.1	-2.0	22.1	14.9	-1.4	Disp.	-	Cumple
				G, V, N	315.2	-12.6	55.0	29.6	-2.4	N,M	98.1	Cumple
P16	F1 (-0.48 - 2.64 m)	30x30	Cabeza	G, Q, S	30.5	5.3	-9.1	11.9	-3.7	Q S.	32.1	Cumple
			Pie	G, Q, S	36.7	-5.2	24.6	11.9	-3.7	N,M S.	74.5	Cumple
	Dep�sito	30x30	Arranque	G	23.7	-3.1	4.2	1.9	-2.5	Disp.	-	Cumple
				G, Q, S	36.7	-5.2	24.6	11.9	-3.7	N,M S.	74.5	Cumple
P11	F1 (-0.48 - 2.64 m)	30x30	Cabeza	G, Q, S	58.8	-5.0	0.4	1.6	5.2	Q S.	12.7	Cumple
			Pie	G, Q, S	65.1	9.5	5.0	1.6	5.2	Q S.	12.5	Cumple
				G, Q, S	63.9	-0.6	15.4	5.0	0.1	N,M S.	30.8	Cumple
	Dep�sito	30x30	Arranque	G	51.2	0.1	3.8	1.2	0.3	Disp.	-	Cumple
				G, Q, S	65.1	9.5	5.0	1.6	5.2	Q S.	1.5	Cumple
				G, Q, S	63.9	-0.6	15.4	5.0	0.1	N,M S.	30.8	Cumple
P8	F1 (-0.48 - 2.64 m)	30x30	Cabeza	G, Q, S	59.5	5.7	0.5	2.1	-6.0	Q S.	14.8	Cumple
			Pie	G, Q, S	65.7	-11.1	6.4	2.1	-6.0	Q S.	14.5	Cumple
				G, Q, S	64.8	-2.2	17.0	5.5	-1.5	N,M S.	36.0	Cumple
	Dep�sito	30x30	Arranque	G	51.7	-1.4	4.2	1.4	-1.0	Disp.	-	Cumple
				G, Q, S	65.7	-11.1	6.4	2.1	-6.0	Q S.	1.8	Cumple
				G, Q, S	64.8	-2.2	17.0	5.5	-1.5	N,M S.	36.0	Cumple
P7	F1 (-0.48 - 3.1 m)	30x30	Cabeza	G, S	194.2	-9.0	0.8	3.3	9.1	Q S.	16.2	Cumple
				G, Q	307.8	-15.1	9.0	2.9	2.7	N,M	30.9	Cumple
			Pie	G, S	200.5	23.2	16.7	3.3	9.1	N,M S.	48.0	Cumple
	Dep�sito	30x30	Arranque	G	167.2	2.0	4.5	1.6	1.4	Disp.	-	Cumple
				G, S	200.5	23.2	16.7	3.3	9.1	N,M S.	48.0	Cumple
P3	F1 (-0.48 - 3.1 m)	30x30	Cabeza	G, S	21.2	-1.3	-19.8	20.0	1.4	Q S.	46.0	Cumple
				G, V, N	29.1	-0.1	-19.6	18.9	0.2	N,M	39.7	Cumple